

Brackish Water Desalination in El Paso

Nine Years In and Planning for the Future

Jeremy Anderson, P.E.

September 2016

The CDM Smith logo, featuring the text "CDM" stacked above "Smith" in a bold, white, sans-serif font, set against a blue background.A decorative horizontal bar consisting of a green square on the left, followed by four blue squares of varying shades, and a blue square on the right containing a close-up image of water droplets.


WATER + ENVIRONMENT + TRANSPORTATION + ENERGY + FACILITIES



Kay Bailey Hutchison Desalination Facility

- El Paso Water Utilities
- 27.5 mgd delivered capacity
 - 15mgd RO permeate
 - 12.5mgd blend well water
- Startup in 2007
- Used as “reserve capacity” plant when other sources are limited
- 3 mgd (1 skid) continuous permeate production






Water Supply

Brackish and Fresh Wells in the Hueco Bolson

- 15 Source Wells
 - For RO Feed
 - Production and Water Quality Declining

- 16 “Blend” Wells
 - Each produce 700-1000 gpm
 - Subject to Ft. Bliss Royalty Fee:
 - \$35/AF or \$100/AF
 - Water Quality Declining




A microscopic view of numerous small, clear water droplets or bubbles, some of which are clustered together, set against a light blue background. This image is positioned on the left side of the slide, partially overlapping a green vertical bar.

The Challenge


Source Water Quality and Quantity

- Declining Water Quality → Higher RO Operation
 - Re-drilled, deeper wells=higher TDS
 - Design: 1200-1500 mg/L
 - Current: Average 2660 mg/L
- Production Rate Declining in Source Wells
 - Water level dropping, minimum feed pressure to RO plant
 - More wells required for same production



Increase in Feed TDS → Decrease in Blend Ratio


- RO permeate quality & production not significantly impacted
- RO feed pumps currently running at ~100%



Using Blend Wells for RO feed is Inefficient and Costly

Recent Peak Day Operation (August 24, 2013)


Current Operation Uses Some
Series 600 Supply for RO Feed,



Use Freshwater Blend Wells for Blending Only

Recommended Peak Operation

*We recommend using only
Source Wells for RO Feed*





Plans for the Future

Immediate Improvements

Needed to maintain 27.5 mgd production

- Projects underway
 - Rehab source wells (underway)
 - Modelling for “bottleneck” in source well delivery network
 - Upgrade deficiencies in source well network
 - “Freshwater Express” pipeline for wells 601-609
- Upcoming Improvements
 - Replace RO Membranes
 - Install Interstage Boosters

Need for Expansion

- Drought conditions mean shorter irrigation season= less surface water available for less time
- KBH is Critical when surface water (Rio Grande) is not available.
 - No surface water in non-irrigation season (winter)
 - Supplements a finite supply of fresh groundwater wells
- In summer, KBH provides peaking capacity to support surface water plants. In winter, provides (emergency) high capacity supply
- Supplies base demand in nearby service area + Ft Bliss
- With water quality decline, blending ratio decreases= total production drops

Phase 1- Near Term Improvements

- Add 6th skid in existing building (3 mgd)
- ~7 new wells and collector pipeline (minimum 3.6 mgd supply)
- Manage increase in concentrate with brine minimization (EWM partnership)
 - Well injection currently limited by pipeline capacity and permit restrictions
- 3-7 year timeline




Phase 2- Long Term Improvements

- Increase permeate production capacity by 12 mgd to a total of 30 mgd
 - New treatment building
 - Additional finished water pumping capacity
- 20+ new wells
 - Each well only ~500 gpm
- Concentrate Management:
 - Install parallel (20") concentrate pipeline to injection wells
 - Add 1-2 new concentrate disposal wells
 - Improvements to concentrate pump station
 - Ongoing Coordination with EWM
- 8-10 year timeline

Phase 2- Wellfield Addition

- “700 Series” wellfield at full buildout
- 20 new wells, in addition to Phase 1
- 500-700 gpm each
- Total Supply: 20 mgd
- 4+ miles of additional collector pipeline



Ultimate Buildout

- Net finished water production: 42.5+ mgd on peak day
- Will run at max capacity only seasonally and as “emergency” supply
- Continued blending of 12 mgd with 30 mgd permeate, due to degrading blend water quality
- \$120 M capital investment (preliminary)

Thank you!



- Special thanks to El Paso Water Utilities
 - Scott Reinert, PE
- CDM Smith Colleagues
 - Jim Steele, PE
 - Horacio Juarez, PE
 - Doug Brown, PE

Source Well Data


	Well#	Flow, gpm	Chloride, mg/L	TDS, mg/L
	47	0	3000	7000
	72	944	1100	1900
	97	900	900	1900
	98	1000	1150	2495
	503A	650	1200	2500
	504A	820	1625	3476
	505A	900	999	2610
	507A	1030	1303	2588
	508	700	343	743
	509A	450	1753	4255
	510A	700	1990	4512
	511A	502	1770	3828
	512A	610	1184	2513
	513A	1000	1177	2475
	514A	978	1296	2710
	515	920	1407	2808
	Total Flow	12104		
	Composite Water Quality		1249	2664

Blend Well Data

Blend wells			
Well No	Capacity ¹ (gpm)	Chloride (mg/l)	TDS ² (mg/l)
601	880	90	422
602	600	101	425
603	805	155	604
604	780	188	609
605	835	285	687
606	710	325	797
607	825	393	1095
608	850	414	1014
609	800	498	1414
610	700	353	1116
611	752	362	1184
612	800	851	3260
613	725	1122	3878
614	850	1167	2306
615	715	1269	1430
616	770	1118	2618
Totals	12397	542.7268	1428.823
	17.85282		

Phase 1- Wellfield Addition

- 7 new wells in short-term
- 500-700 gpm each
- New 2-mile collector pipeline to KBH
- “700 series” wellfield
- Wells located on Ft Bliss, subject to “royalty fee” (\$/af TBD)
- Water quality expected: 2000-4000 mg/L TDS



KBH